

# The Seismic Assessment of Existing Buildings

## Technical Guidelines for Engineering Assessments

Revised Draft – 10 October 2016

### Section C3 – Earthquake Demands



New Zealand Society for  
Earthquake Engineering



MINISTRY OF BUSINESS,  
INNOVATION & EMPLOYMENT  
HIKINA WHAKATUTUKI



## Document Status and Amendments

Version	Date	Purpose/ Amendment Description
2016_SB	30 June 2016	Draft for Sector Briefings
2016_C	10 Oct 2016	Revised draft to accompany consultation proposals for the regulations and EPB methodology under the <i>Building (Earthquake-prone Buildings) Amendment Act 2016</i>

This document is intended to be referenced by the Earthquake Prone Buildings (EPB) Methodology being developed under the provisions of the Building (Earthquake-prone Buildings) Amendment Act 2016. It is also intended to be endorsed by MBIE for use as guidance under section 175 of the Building Act 2004 to the extent that it assists practitioners and territorial authorities in complying with that Act.

### Document Access

This draft document may be downloaded from [www.EQ-Assess.org.nz](http://www.EQ-Assess.org.nz) in parts:

- 1 Part A – Assessment Objectives and Principles
- 2 Part B – Initial Seismic Assessment
- 3 Part C – Detailed Seismic Assessment

Updates will be notified on the above website.

The document is expected to be published before the Act comes into force, when the regulations and EPB Methodology associated with the Building (Earthquake-prone Buildings) Amendment Act 2016 come into force.

### Document Management and Key Contact

This document is managed jointly by the Ministry of Business, Innovation and Employment, the Earthquake Commission, the New Zealand Society for Earthquake Engineering, the Structural Engineering Society and the New Zealand Geotechnical Society.

Please use the feedback forms on [www.EQ-Assess.org.nz](http://www.EQ-Assess.org.nz) to provide feedback or to request further information about these draft Guidelines.

## Acknowledgements

These Guidelines were prepared during the period 2014 to 2016 with extensive technical input from the following members of the Project Technical Team:

Project Technical Group Chair	
Rob Jury	Beca
Task Group Leaders	
Jitendra Bothara	Miyamoto International
Adane Gebreyohanness	Beca
Nick Harwood	Eliot Sinclair
Weng Yuen Kam	Beca
Dave McGuigan	MBIE
Stuart Oliver	Holmes Consulting Group
Stefano Pampanin	University of Canterbury

Other Contributors	
Graeme Beattie	BRANZ
Alastair Cattanach	Dunning Thornton Consultants
Phil Clayton	Beca
Charles Clifton	University of Auckland
John Hare	Holmes Consulting Group
Jason Ingham	University of Auckland
Stuart Palmer	Tonkin & Taylor
Lou Robinson	Hadley & Robinson
Craig Stevenson	Aurecon
Dmytro Dizhur	University of Auckland
Helen Ferner	Beca
Justin Coe	MBIE

Project Management was provided by Deane McNulty, and editorial support provided by Ann Cunninghame and Sandy Cole.

Oversight to the development of these Guidelines was provided by a Project Steering Group comprising:

Dave Brunson (Chair)	Kestrel Group
Gavin Alexander	NZ Geotechnical Society
Stephen Cody	Wellington City Council
Jeff Farrell	Whakatane District Council
John Gardiner	MBIE

John Hare	SESOC
Quincy Ma	NZSEE
Richard Smith	EQC
Mike Stannard	MBIE
Frances Sullivan	Local Government NZ

Funding for the development of these Guidelines was provided by the Ministry of Business, Innovation and Employment and the Earthquake Commission.



# Contents

<b>C3. Earthquake Demands .....</b>	<b>C3-1</b>
<b>C3.1 General.....</b>	<b>C3-1</b>
C3.1.1 Outline of this section .....	C3-1
C3.1.2 Definitions and abbreviations .....	C3-1
C3.1.3 Notation .....	C3-1
<b>C3.2 Method for Deriving ULS Seismic Demand.....</b>	<b>C3-2</b>
C3.2.1 General.....	C3-2
C3.2.2 Available representations .....	C3-3
<b>C3.3 Horizontal Acceleration Response Spectra .....</b>	<b>C3-4</b>
<b>C3.4 Horizontal Displacement Response Spectra .....</b>	<b>C3-5</b>
<b>C3.5 Horizontal Acceleration-Displacement Response Spectra (ADRS) .....</b>	<b>C3-8</b>
<b>C3.6 Vertical Acceleration Response Spectra.....</b>	<b>C3-10</b>
<b>C3.7 Acceleration Ground Motion Records .....</b>	<b>C3-10</b>
<b>C3.8 Representations for Geotechnical Considerations.....</b>	<b>C3-10</b>
<b>C3.9 Other Issues .....</b>	<b>C3-11</b>
C3.9.1 Site-specific probabilistic seismic hazard analysis.....	C3-11
C3.9.2 Incorporation of the structural performance factor, $S_p$ .....	C3-11
C3.9.3 Demands on secondary structural and non-structural elements .....	C3-11
C3.9.4 Application of ULS loading (actions) .....	C3-11
<b>References.....</b>	<b>C3-12</b>



## C3. Earthquake Demands

### C3.1 General

#### C3.1.1 Outline of this section

This section sets out the intended method for deriving the ULS seismic demand, which is needed to evaluate the %NBS seismic rating in accordance with Sections C1.5.1 and C1.5.6. It also lists the available representations of the ULS seismic demand and explains what is intended for these.

#### C3.1.2 Definitions and abbreviations

ADRS	Acceleration-displacement response spectra
IL	Importance level of a building, as defined in AS/NZS 1170.0:2002
Importance Level (IL)	Categorisation defined in the New Zealand Loadings Standard, NZS 1170.0:2002 used to define the ULS shaking for a new building based on the consequences of failure. A critical aspect in determining new building standard.
PGA	Peak ground acceleration.
Site subsoil class	Categorisation of the soil profile under the building in accordance with NZS 1170.5:2004
ULS	Ultimate Limit State
Ultimate limit state (ULS)	A limit state defined in the New Zealand loadings standard NZS 1170.5:2004 for the design of new buildings
SLaMA	Simple Lateral Mechanism Analysis (refer to Section C2)
100%ULS seismic demand	Seismic demand used in the calculation of %NBS. Can be represented in a number of ways depending on the aspect under consideration.

#### C3.1.3 Notation

Symbol	Meaning
%NBS	Percentage of new building standard (refer to Section C1)
$K_{\delta}(T)$	Displacement spectral scaling factor. Varies depending on the building period, $T$ .
$k_{\mu}$	Inelastic spectrum scaling factor as defined in NZS 1170.5:2004
$K_{\xi}$	Spectral damping reduction factor (refer to Section C3.3).
$R$	Return period factor. Will typically be $R_u$ determined in accordance with NZS 1170.5:2004.
$R_u$	Return period factor appropriate for the ULS. Determined in accordance with NZS 1170.5:2004
$S_a$	Spectral acceleration
$S_d$	Spectral displacement
$S_p$	Structural performance factor. Determined in accordance with NZS 1170.5:2004

Symbol	Meaning
$T$	Period(s) of vibration for the building
$T_1$	First mode period of vibration of the building
$U_{\text{eff}}$	Lateral displacement at the effective (equivalent) height. Refer to Section C2.
$V$	Base shear
$W$	Total weight of the structure
$\xi_{\text{sys}}$	Equivalent viscous damping of the system
$\pi$	Refer to Equation C3.2, Section C3.5 and Equation C3.5

## C3.2 Method for Deriving ULS Seismic Demand

### C3.2.1 General

The basis for the derivation of ULS seismic demand is the New Zealand earthquake loadings standard NZS 1170.5:2004 and of the New Zealand Geotechnical Society and Ministry of Business, Innovation and Employment’s Module 1 – Geotechnical Earthquake Engineering Practice” series (NZGS/MBIE, 2016). These are assumed to define 100% ULS seismic demand or, in other words, the seismic demand that would be used to design a similar new building at the time the assessment is completed.

#### Note:

Seismic demand for the purposes of defining an earthquake-prone building in accordance with these guidelines has been set in legislation as that which would have been obtained for the design of a new building from NZS 1170.5:2004 (including amendment 1.) and Module 1 of the Geotechnical Earthquake Engineering Practice series dated March 2016. These documents define the seismic demand that was current at the time the legislation was enacted, which is the relevant basis for the ULS seismic demand used to calculate the earthquake-prone threshold adopted in these guidelines of 34%NBS.

It is intended that the basis for setting the seismic demand for determining %NBS generally is the demand determined in accordance with the versions of the above documents that are current at the time the assessment is completed.

The importance level (IL) used for the evaluation of the ULS seismic demand shall be derived from AS/NZS 1170.0:2002 based on the use/intended use of the building.

For the purposes of deriving the ULS seismic demand, the design life shall not be taken as less than 50 years unless a lower design life has been formally established with the relevant building consent authority/territorial authority.

#### Note:

An argument can be raised that life safety risks should not be affected by the chosen design life of the building. The rationale for this is that the life safety risk exists at any point in time (say, expressed as an annual risk) and is not affected by the total exposure period, whereas the exposure period is relevant when considering the potential economic losses (for example) over the life of the building.



While the concept of a design life less than 50 years is allowable under AS/NZS 1170.0:2002, this is on the assumption that the building will be removed when this period expires and that this intention will be noted on the building file held by the building consent authority/territorial authority. This should also apply if a building is assessed from a regulatory point of view or a consent for alteration (retrofit) is applied for. It is not intended that a chosen design life of less than 50 years is simply rolled over in perpetuity. In accordance with the intent of the New Zealand Building Code a 50 year exposure period (design life) is considered to represent an indefinite design life.

### C3.2.2 Available representations

Representation of the ULS seismic demand will vary depending on the method of analysis and the particular aspect being assessed.

The range of available representations includes:

- acceleration response spectra
- displacement response spectra
- acceleration-displacement response spectra (ADRS)
- ground acceleration, velocity or displacement strong motion records
- peak ground acceleration (PGA), ground displacements, characteristic earthquakes, numbers of cycles for geotechnical considerations, and
- inter-storey drifts and total deformation between supports for elements supported on ledges.

When using time history analysis techniques it may be appropriate to determine the %NBS by scaling input motions. In these circumstances the scaling should only be applied to the ground accelerations and displacements and not to the duration of shaking, which should remain as appropriate for the ULS.

Likewise, when running traditional analysis for a target %NBS (say 34%NBS for a simple earthquake-prone check) it is only the response spectral ordinates that are scaled. The duration of shaking remains unchanged from that implied by the 100%ULS seismic demands.

#### Note:

While it is acknowledged that some assessors will be more familiar with the elastic based representations of NZS 1170.5:2004 and the allowance for ductility through application of an assumed global ductile capability, the thrust of these guidelines is to take account of the nonlinear deformation capability of the building directly using the displacement based simple lateral mechanism analysis (SLaMA) approach and the ADRS representation of the seismic demand.

### C3.3 Horizontal Acceleration Response Spectra

When a horizontal acceleration response spectrum is used to establish the ULS seismic demand, the spectrum shall be derived in accordance with NZS 1170.5:2004 Clauses 5.2.2.1 and 5.2.2.2 including an appropriate value for  $S_p$ , which may vary depending on the particular aspect being assessed (refer to Section C3.9.2).

When required, horizontal acceleration response spectra for different damping values may be obtained by multiplying the spectral ordinates of the 5% damped elastic spectrum determined as above (i.e. setting  $k_\mu = 1$ ) by the spectral damping reduction factor,  $K_\xi$ :

$$K_\xi = [7/(2 + \xi_{\text{sys}})]^{0.5} \quad \dots\text{C3.1}$$

where:

$\xi_{\text{sys}}$  = equivalent viscous damping of the system (refer to Appendix C2D for calculation of  $\xi_{\text{sys}}$ ).

#### Note:

Priestley et al. (2007) provides some guidance on damping and the resulting reduction in spectral demand for seismic assessment. Equation C3.1 is presented as part of this guidance.

While Kong and Kowalsky (2016) have recently noted that the above equation appears to be quite reasonable for large magnitude events, studies such as those by Akkar et al. (2014) and Rezaeian et al. (2014) indicate that the actual damping-dependent spectral scaling factor should be a function of several factors including magnitude, epicentral distance (and depth) and period of vibration.

Pennucci et al. (2011), on the other hand, demonstrated that more representative inelastic (effective period) spectra for use with the displacement-based design/assessment approach could be obtained by scaling the displacement spectrum using ductility-dependent, as opposed to damping-dependent, spectral scaling factors. However, Pennucci et al. (2011) also point out that scaling factors should be a function of spectral shape and the results presented by Stafford et al. (2016) indicate that such inelastic spectra should again depend on magnitude and period.

For sites affected by near-field ground motions containing velocity pulses, Priestley et al. (2007) recommended changing the exponent within Equation C3.1 from 0.5 to 0.25 to account for the limited benefit of hysteretic energy dissipation characteristics on inelastic displacement demands induced by velocity pulse characterised near-field motions.

However, results presented in Sullivan et al. (2013) suggest that when the effective period of a structure is assessed to be less than the velocity pulse period for the site then no change is required to the scaling recommended for far-field motions. In contrast, when the velocity pulse period is equal to or larger than the pulse period, the inelastic displacement demands tend to be equal to the elastic spectral displacement demands (suggesting no benefit of hysteretic response).

Near-fault effects have traditionally been associated with larger magnitude earthquakes. However, Bradley (2015) indicated that near-fault effects were also discernible in the moderate magnitude Christchurch near-fault events.

NZS 1170.5:2004 currently adjusts the acceleration response hazard spectrum for near field effects using the near-fault factor. This addresses the increased amplitude of the expected motion for larger magnitude earthquakes (also taking into account the directional nature on the expected frequency of occurrence) but does not otherwise address the effect of the reduction in the ability to dissipate energy, and therefore the reduced effect of the ability of nonlinear behaviour (ductility) to reduce a building's response.

It is clear that additional research is needed to determine how best to account for near-field effects in design and assessment and the extent to which this phenomenon needs to be allowed for. It might be expected that future revisions of NZS 1170.5:2004 will need to address this issue which may increase demand requirements. This could also lead to the need to reconsider the level of damping that might be available and the expected effect of this. However, in the interim, it is recommended that Equation C3.1 continue to be used for all sites.

### C3.4 Horizontal Displacement Response Spectra

For displacement based methods, a displacement response spectrum is required. For the purposes of these guidelines it is considered appropriate to derive the 5% damped spectral displacement spectrum by multiplying the ordinates of the 5% damped elastic acceleration spectrum from Section C3.2 by the factor:

$$K_{\delta}(T) = 9800T^2/4\pi^2 \quad \dots\text{C3.2}$$

Displacement spectra for different damping values may be obtained by multiplying the 5% damped displacement spectrum by the factor,  $K_{\xi}$ , calculated using Equation C3.1.

Figure C3.1 illustrates the shape of the resulting displacement spectra for Wellington, Christchurch and Auckland for different subsoil conditions. The effect of the application of  $K_{\xi}$  is illustrated in Figure C3.2.







Figure C3.1: Displacement spectra at 5% damping for  $R = 1$ ,  $S_p = 1$  for various site subsoil classes and including appropriate near fault factor



**Figure C3.2: Displacement spectra for different damping levels and site subsoil class C and including appropriate near fault factor**

Examination of the displacement spectra in Figures C3.1 and C3.2 reveals several interesting points.

First, the significance of the soil type is much more apparent when seismicity is expressed in terms of displacement, rather than acceleration, spectra.

Second, apart from some nonlinearity for low periods, the curves are well represented by straight lines from the origin as shown on Figure C3.2. For sites where near-fault effects are not an issue the displacement spectra are well represented by a bilinear relationship pivoting around the displacement at  $T = 3$  seconds and with a horizontal leg beyond 3 seconds. For a site where near-fault effects are specified the displacement spectra can be approximated by a bilinear relationship between  $T = 0, 3$  and  $4.5$  seconds. These are approximations, the validity of which will need to be confirmed. It is expected that the straight-line approximations indicated are sufficiently accurate to be used as the basis for assessments and design of retrofit works. However, this should not preclude a more precise or direct evaluation should circumstances warrant or allow.

Third, the displacement spectra obtained do not represent the tendency of the spectral displacement to converge to the peak ground displacement at long periods but maintain the spectra conservatively at constant peak displacement response values (or increase these for sites where near-fault effects are specified).

### C3.5 Horizontal Acceleration-Displacement Response Spectra (ADRS)

The acceleration and displacement spectra derived in the previous two sections for a particular site and level of damping can be usefully presented in the form of an acceleration-displacement response spectrum (Mahaney et al., 1993). The ordinates of such a spectrum are spectral acceleration and spectral displacement. An example of such representations is shown in Figure C3.3 for Wellington, Christchurch and Auckland for a 500 year return period ( $R_u = 1$ ),  $S_p = 1$  and site subsoil class C.

When constructing an acceleration-displacement spectrum for a particular level of damping both the acceleration and the displacement ordinates must be multiplied by  $K_\xi$  and the appropriate value of  $S_p$ .

Acceleration-displacement spectra are particularly useful when assessing the %NBS of a building from the results of a nonlinear pushover analysis. The acceleration and displacement results from a pushover analysis need to be converted to spectral acceleration and spectral displacement (as described below) before comparisons are possible with the acceleration-displacement spectra described above.

#### Note:

When a pushover curve has been derived from the combination of various structural systems of different ductile capability (using, for example, the SLaMA method), it may be more useful to incorporate the various  $S_p$  factors into the combined system pushover curve and compare against the ADRS calculated assuming  $S_p = 1$  (refer to Section C3.9.2).

The conversion can be carried out as follows, assuming that elastic response is a good predictor of inelastic response (this will not always be the case):

$$S_a = V/W \quad \dots C3.3$$

$$S_d = U_{\text{eff}} \quad \dots C3.4$$

where:

- $V$  = base shear consistent with  $U_{eff}$
- $W$  = total weight of the structure
- $U_{eff}$  = lateral displacement at the effective (equivalent) height (refer to Section C2)




Figure C3.3: Acceleration-displacement spectra for different damping levels for  $R = 1$ ,  $S_p = 1$  and site subsoil class C

Note that the first mode period,  $T_1$ , can be approximated (assuming predominantly first mode response) from the relationship:

$$T_1 = 2\pi \sqrt{S_d/S_a} \quad \dots C3.5$$

where:

$S_a$ ,  $S_d$  are as defined above.

Thus the stiffness of the building ( $T$ ) can be represented by radiating lines from the origin of the acceleration-displacement spectrum. These lines, for example periods of 0.5, 1.0 and 1.5 sec, are shown in Figure C3.3.

**Note:**

ATC 40 (1996) presents an excellent discussion on the way in which the acceleration-displacement spectrum can be derived and used to assess the performance of buildings. Refer to Section C2 for the use of ADRS with nonlinear static pushover analysis and in particular with SLaMA.

## C3.6 Vertical Acceleration Response Spectra

When a vertical response spectrum is required to establish the ULS seismic demand, the spectrum shall be derived from NZS 1170.5:2004, Clause 5.4.

## C3.7 Acceleration Ground Motion Records

When acceleration ground motion records are required, their selection and scaling shall meet the requirements of NZS 1170.5:2004, Clause 5.5.

The input earthquake records shall either contain at least 15 seconds of strong motion shaking or have a strong shaking duration of at least five times the fundamental period of the structure, whichever is greater.

All three components of any ground motion records should be used where all components are scaled by the same factor which is determined separately for each direction of application of the principal component. When scaled ground motion records are used to establish a %NBS other than 100%NBS, only the acceleration ordinates should be scaled. The duration of shaking established for the ULS seismic demand should not be changed.

## C3.8 Representations for Geotechnical Considerations

The ULS seismic demand for geotechnical considerations, including PGA, representative (effective) earthquake magnitude and number of cycles, should be derived in accordance with the requirements of Module 1 of the Geotechnical Earthquake Engineering Practice series (NZGS/MBIE, 2016).



## **C3.9 Other Issues**

### **C3.9.1 Site-specific probabilistic seismic hazard analysis**

Site-specific probabilistic seismic hazard analyses should be completed in accordance with the requirements of NZS 1170.5:2004 and Module 1 of the Geotechnical Earthquake Engineering Practice series (NZGS/MBIE, 2016) as appropriate. The constraints noted in the Verification Method B1/VM1 (for New Zealand Building Code Clause B1 Structure) regarding the results from a site specific hazard analysis apply.

### **C3.9.2 Incorporation of the structural performance factor, $S_p$**

The appropriate value of the structural performance factor,  $S_p$  needs to be used when assessing the ULS seismic demand for structural considerations. This may require different values for  $S_p$  depending on the level of nonlinear deformation possible from the aspect under consideration, as determined in accordance with NZS 1170.5:2004 and this section.

$S_p$  may be used either to reduce the demand spectral values calculated above (this is the approach adopted in NZS 1170.5:2004) or used to enhance the global capacity as assessed later in these guidelines. If the latter option is used, then for the purposes of establishing the ULS seismic demand  $S_p$  would need to be taken as 1.0.

As  $S_p$  is dependent on the structural ductility available it is likely that the  $S_p$  factor will only be able to be set once the available global ductility has been determined from the global deformation capacity of the building.

$S_p$  is not used for geotechnical considerations.

### **C3.9.3 Demands on secondary structural and non-structural elements**

The ULS seismic demand on secondary structural and building parts should be determined in accordance with Section 8 of NZS 1170.5:2004. The demand may be in the form of loads/forces or deformations. Further guidance is provided in Sections C2 and C10.

### **C3.9.4 Application of ULS loading (actions)**

The direction of application of the specified actions and the allowances for accidental eccentricity should meet the requirements of NZS 1170.5:2004, Clause 5.3.

Where the actions for an element are influenced by more than one direction of loading (e.g. a corner column in a moment resisting frame building) and the load on the element cannot be limited by a yielding mechanism, the application of the ULS actions may be as for a nominally ductile structure.

## References

- Akkar, S., Sandikkaya, M.A. and Ay, B.O. (2014). *Compatible ground-motion prediction equations for damping scaling factors and vertical-to-horizontal spectral amplitude ratios for the broader Europe region*, Bulletin Earthquake Engineering, Vol 12 pg 517-547.
- AS/NZS 1170.0:2002. *Structural Design Actions – Part 0: General Principles*, Australian/New Zealand Standard, 2002.
- ATC 40 (1996). *Seismic evaluation and retrofit of concrete buildings*, Vol 1 & 2 Applied Technology Council, Redwood CA, Nov 1996.
- Bradley, B.A. (2015). *Period Dependence of Response Spectrum Damping Modification Factors due to Source- and Site-Specific Effects*, Earthquake Spectra, Vol. 31 (2): 745–759.
- New Zealand Geotechnical Society (NZGS) and Ministry of Business, Innovation and Employment (MBIE) Modules. *Earthquake Geotechnical Engineering Practice-Module 1 Geotechnical earthquake engineering practice in New Zealand*, Geotechnical Earthquake Engineering Practice series, March 2016., www.nzgs.org
- Kong, C. and Kowalsky, M.J. (2016). *Impact of Damping Scaling Factors on Direct Displacement-Based Design*, Earthquake Spectra, In press.
- Mahaney, J.A., Paret, T.F. Kehoe, B.E. and Freeman, S.A. (1993). *The Capacity Spectrum Method for Evaluating Structural Response During the Loma Prieta Earthquake*, Proceedings of the 1993 National Earthquake Conference, Earthquake Hazard Reduction in the Central and Eastern United States: A Time for Examination and Action, Memphis, Tennessee, May 2-5, 1993, Vol. II, 1993.
- NZS 1170.5:2004. *Structural Design Actions, Part 5: Earthquake actions – New Zealand*, Standards New Zealand, Wellington, New Zealand.
- Pennucci, D., Sullivan, T.J., and Calvi, G.M. (2011). *Displacement Reduction Factors for the Design of Medium and Long Period Structures*, Journal of Earthquake Engineering, Vol. 15, Supplement 1, 1-29.
- Priestley M.J.N., Calvi G.M. and Kowalsky M.J. (2007). *Displacement-based seismic design of structures*, IUSS Press. Pavia, Italy.
- Rezaeian, S., Bozorgnia, Y. Idriss, I.M., Abrahamson, N.A., Campbell, K.W. and Silva, W.J. (2014). *Damping scaling factors for vertical elastic response spectra for shallow crustal earthquakes in active tectonic regions: “average” horizontal component*, Earthquake Spectra Vol. 30, page 939-963.
- Stafford, P., Sullivan, T.J. and Pennucci, D. (2016). *Empirical correlation between inelastic and elastic spectral displacement demands*, Earthquake Spectra, in press.
- Sullivan, T.J., Pennucci, D., Piazza, A., Manieri, S., Welch, D.P. and Calvi, G.M. (2013). *General aspects of the displacement based assessment approach*, in Developments in the Field of Displacement-Based Seismic Assessment, Edited by Sullivan, T.J., Calvi, G.M., IUSS Press, Pavia, Italy, ISBN; 978-88-6198-090-7.